Name:	Vent-Axia
Model ID (Stock Ref.) :	HR 200 V - 14120010 - LDC
SEC Class	А
SEC Value ('Average')	-35.24
SEC Value ('Warm')	-12.25
SEC Value ('Cold')	-76.16
Label Required? (Yes/No=Out of scope)	Yes
Declared as: RVU or NRVU/UVU or BVU	RVU/BVU
Speed Drive	Multi-Speed
Type HRS (Recuperative, Regenerative, None)	Recuperative
Thermal Eff: [ (%), NA(if none)]	70.00
Max. Flow Rate (m3/h)	198.00
Max. Power Input (W): (@Max.Flow Rate)	110.00
LWA: Sound Power Level (dB)	66.13
Ref. Flow Rate (m3/s)	0.03850
Ref. Pressure Diff. (Pa)	80.00
SPI [W/(m3/h)]	0.43
Control Factor & Control Typology: (CTRL/ Typology)	
Control Factor; CTRL	0.65
Control Typology	Local Demand Control
Declared: -Max Internal & External Leakage Rates(%) for BVUs or carry	
over (for regenerative heat exchangers only),	<5% Internal, <5% External
-&Ext. Leakage Rates (%) for Ducted UVUs;	
Mixing Rate of Non-Ducted BVUs not intended to be equipped with	
one duct connection on either supply or extract air side;	N/A
Position and description of visual filter warning for RVUs intended for	
use with filters, including text pointing out the importance of regular	N/A
filter changes for performance and energy efficiency of the unit	
For UVUs (Instructions Install Regulated Supply/Extract Grilles Façade)	N/A
Internet Address (for Disassembly Instructions)	www.vent-axia.com
Sensitivity p. Variation@+20/-20 Pa: (for Non-Ducted VUs)	N./A
Air Tightness-ID/OD-(m3/h) (for Non-Ducted VUs)	N./A
Annual Electricity Consumption: AEC (kWh/a)	3.29
Annual Heating Saved: AHS (kWh/a)	
AHS: Average	42.79
AHS: Warm	19.35
AHS: Cold	83.71